

No. 2835/MIHAN/FIRE/2022

To,
Director,
Bhartiya Vidya Bhavan
Lala Lajpatrai Marg, Near Museum,
Civil Lines, Nagpur.440001

Subject : Regarding fire fitness certificate for proposed Pre primary, Primary and Secondary School having (partly Ground & partly stilt) + 6 floor) of Bhartiya Vidya Bhavan , Chinchbhuvan, Wardha Road Nagpur.

- Ref. :1) Application No.BVB-NGP/DCFO/2022-23/2309, dtd.17.06.2022, received on dtd.20.06.2022
2) Certificate from A.B.Dongre Architect on dtd.17.06.2022, received on 20.06.22
3) This office letter No.2835/MIHAN/FIRE/2022 dtd.09.06.2022, for deviation.
4) Provisional fire NOC No.1516/MIHAN/FIRE/2019 on dtd.11.03.2019
5) Part fire fitness certificate No.4951/MIHAN/FIRE/2019 for school building G+1st Floor
6) Part fire fitness certificate No.2935/MIHAN/FIRE/2020 dtd.16.09.2020 for school building 2nd & 3rd floor

With reference to above subject that the Letter received from Director, Bhartiya Vidya Bhavan, Chinchbhuvan, Nagpur. Application No. BVB-NGP/DCFO/2022-23/2309, dtd.17.06.2022 proposed Pre primary, Primary and Secondary School having (partly Ground & partly stilt) + 6 floor) of Bhartiya Vidya Bhavan , Chinchbhuvan, Wardha Road Nagpur With the application 'A' form from license holder company M/s. Advantage sai having License No. MFS-LA/RF-200,MFS-LA/RD-184,with Annexure for Execution / Maintenance, Lift certificate form M/s Johnson Lifts & Escalators, Form "N" from Govt. Maharashtra, Director of MFS. having License No. MFS-LA/RF-200,MFS-LA/RD-184, and Photos are enclosed herewith. Dy.Chief Fire Officer, MADC visited the site on dtd.20.06.2022. As per the letters received form Bhartiya Vidya Bhavan Nagpur dtd.17.06.2022.

The Provisional Fire No Objection Certificate No.1516/MIHAN/FIRE/2019 dtd.11.03.2019 was issue for Pre primary, Primary and Secondary School having (partly Ground & partly stilt) + 6 floor) of Bhartiya Vidya Bhavan , Chinchbhuvan, Wardha Road Nagpur, for the construction & installation of fire protection prevention and safety arrangements as per NBC norms.

Therefore the Fire Fitness Certificate is hereby granted proposed Pre primary, Primary and Secondary School having (partly Ground & partly stilt) + 6 floor), Chinchbhuvan, Wardha Road Nagpur on following term & condition.

Terms & conditions:-

- 1) Fire Fitness Certificate is granted for one year only.
- 2) Fire Fitness Certificate to be renew every year from MADC, Nagpur.

Maharashtra Airport Development Company Ltd.

(A Government of Maharashtra Undertaking)

CIN:U45203MH2002SGC136979

Central Facility Building, B-Wing (North), 1st Floor, MIHAN SEZ, Khapri (Rly.), Nagpur - 441 108

Phone: +91-7104-665665 ● Fax: +91-7104-665600 ● Email: jmd@madcindia.org

● Website: <https://madc.maharashtra.gov.in>

E:\Vishwas\Doc\Fire\Dy CFO\June -22\FFC Bhavans 200622.doc


PRINCIPAL

Bhavan's B. P. Vidya Mandir
Chinchbhuvan, Nagpur-15




SMT. A. SHASTRI
DIRECTOR
Bhartiya Vidya Bhavan
Civil Lines, Nagpur-1

- 3) Open space should be kept free of obstructions around the building.
- 4) All staff and guards should be trained to operate and handling fire fighting equipments.
- 5) Emergency Plan should be prepared.
- 6) For Fire Fighting rescue & evacuation mock drill carried out once in a 6 months.
- 7) Applicant should properly maintain all fire fighting, fire protection, fire prevention & safety equipment installation regularly.
- 8) MADC reserve the right to amend/change condition or impose new conditions considering the safety requirements of life, property, building, & surroundings.
- 9) The condition of the certificate shall be binding not only the applicant but also its successors and every persons deriving title through or under him.
- 10) Every year there will be inspection by Fire Officer of MADC.
- 11) During the occupancy of the building if anything happens due to non compliance all the responsibility will lies with Bhartiya Vidya Bhavan Nagpur and its other professional responsible building development. In no case, MADC shall be held responsible for any lapse of whatever reason by Bhartiya Vidya Bhavan & its other professionals.
- 12) Storage of water for firefighting purpose shall always be available with alternative source of supply.
- 13) Every six month the applicant will inform in written regarding all firefighting & fire safety arraignment are in working condition.
- 14) Applicant should attached "B" form along with renewal application.
- 15) At the time of inspection if the fire fighting & safety installation not found in working condition. as stated in provisional fire NOC . The fire fitness certificate will be cancelled without preintimation.

On above term & conditions the Fire Fitness Certificate is Certificate is hereby granted to Bhartiya Vidya Bhavan proposed Pre primary, Primary and Secondary School having (partly Ground & partly stilt) + 6 floor), Chinchbhuvan, Wardha Road Nagpur

Vaild upto:21.06.2023

[Signature]
21/06/2022
Dy. Chief Fire Officer
Fire & Emergency Services
MADC, Ltd. Nagpur

Copy to: Chief Engineer, MADC Nagpur for information please.



Maharashtra Airport Development Company Ltd.

(A Government of Maharashtra Undertaking)

CIN:U45203MH2002SGC136979

Central Facility Building, B -Wing (North), 1st Floor, MIHAN SEZ, Khapri (Rly.), Nagpur - 441 108

Tel: +91 -7104 -665665 ● Fax: +91-7104-665600 ● Email: jmd@madcindia.org

● Website: <https://madc.maharashtra.gov.in>

E:\Vishwag\Doc\Fire\Dy CFO\June -22\FFC Bhavans 200622.doc

[Signature]
PRINCIPAL
Bhavan's B. P. Vidya Mandir
Chinchbhuvan, Nagpur-15



[Signature]
SMT. A. SHASTRI
DIRECTOR
Bhartiya Vidya Bhavan
Civil Lines, Nagpur-1