

No. 3709 /MIHAN/FIRE/2026

Date: 06/08/2026

Renewal of Fire Safety Approval

To,
M/s Bhavan's Bhagwandas
Purohit Vidya Mandir
Sector-34, chinchbuvan Wardha road,
Nagpur-440015

Subject: Renewal fire safety approval for M/s Bhavan's bhagwandas, Purohit Vidya Mandir Sector-34, chinchbuvan Wardha road, Nagpur-440015

Ref. : 1) Application received from M/s Bhavan's bhagwandas, Purohit Vidya Mandir dtd.16.06.2026. MADC inward No.2733, dtd,16.06.2026.
2) Renewal of Fire Fitness Certificate No.3651, dtd.24.07.2025

As per application from M/s Bhavan's bhagwandas, Purohit Vidya Mandir. for Renewal of fire safety approval for M/s Bhavan's bhagwandas, Purohit Vidya Mandir Sector-34, chinchbuvan Wardha road, Nagpur-440015. Received Form "B" along with application from Advantage sai Projects Pvt Ltd. having license no. MFS/LA/RF-180, RD-184, RP-46 along with attested photographs.

Therefore, the renewal of fire fitness certificate hereby granted for further one-year to M/s Bhavan's bhagwandas, Purohit Vidya Mandir Sector-34, chinchbuvan Wardha road, Nagpur-440015.

Terms & conditions: -

- 1) Renewal of Fire Safety Approval is granted for one year only.
- 2) Renewal of Fire Safety Approval to be renew every year from MADC, Nagpur.
- 3) Open space should be kept free of obstructions around the building.
- 4) All staff and guards should be trained to operate and handling fire fighting equipments.
- 5) Emergency Plan should be prepared.
- 6) For Fire Fighting rescue & evacuation mock drill carried out once in 3 months.
- 7) Applicant should properly maintain all fire fighting, fire protection, fire prevention & safety equipment installation regularly.
- 8) MADC reserve the right to amend/change condition or impose new conditions considering the safety requirements of life, property, building, & surroundings.
- 9) The condition of the certificate shall be binding not only the applicant but also its successors and every person deriving title through or under him.

2



Maharashtra Airport Development Company Ltd.

(A Government of Maharashtra Undertaking)

CIN:U45203MH2002SGC136979

Central Facility Building, B -Wing (North), 1st Floor, MIHAN SEZ, Khapri (Rly.), Nagpur - 441 108

Tel: +91 -7104 -665665 ● Fax: +91-7104-665600 ● Email: jmd@madcindia.org

● Website: <https://madc.maharashtra.gov.in>

D:\Ansari\2026-27 record\NOC\Renewal NOC\RFFC Bhavance.doc

Abhi Lam
Smt. Anju Bhutani
Manager

Raj
PRINCIPAL

Bhavan's B. P. Vidya Mandir
Chinchbuvan, Nagpur-15

- 10) Every year there will be inspection by Fire Officer of MADC.
- 11) During the occupancy of the building if anything happens due to non compliance the fire protection, fire prevention & safety equipment installation as stated in the certificate. The entire responsibility lies with occupier/owner and its other professional responsible building development. In no case, MADC shall be held responsible for any lapse of whatever reason by occupier/owner & its other professionals.
- 12) Storage of water for firefighting purpose shall always be available with alternative source of supply.
- 13) Qualified Fire Officer with experience of not less than 2-3 year shall be appoint who will be available on the premises.
- 14) Remaining part of building and floor should not be occupied without Fire Fitness Certificate.
- 15) Every six month the applicant has to inform in written regarding all firefighting, fire protection, fire prevention, safety arraignments and equipments are in working conditions to fire officer.
- 16) Form "B" from licence agency should be submitted at the time of renewal or January & July.
- 17) At the time of inspection if the fire fighting & safety installation not found in working condition. as stated in provisional fire NOC. The renewal of fire safety approval will be cancelled without preintimation.
- 18) Submit yearly annual electric audit report at the time of renewal of fire safety approval.

Valid up to: 06/08/2027


Dy. Chief Fire Officer
Fire & Emergency Services
MADC, Ltd. Nagpur

Copy to : Officer In charge (PO), MADC Nagpur for information please.


PRINCIPAL
Bhavan's B. P. Vidya Mandir
Chinchbhuvan, Nagpur-15




Smt. Anju Bhutani
Manager

Maharashtra Airport Development Company Ltd.
(A Government of Maharashtra Undertaking)
CIN:U45203MH2002SGC136979

Central Facility Building, B - Wing (North), 1st Floor, MIHAN SEZ, Khapri (Rly.), Nagpur - 441 108
Tel: +91 -7104 -665665 ● Fax: +91-7104-665600 ● Email: jmd@madcindia.org
● Website: <https://madc.maharashtra.gov.in>